

SIR LEAK DETECTION QUICK REFERENCE

MA# Manufacturer	Model	Threshold	Data Days	Single Tank Capacity	Manifolded Aggregate Capacity
20120014 Warren Rogers Assoc. (Renewal for 20090006)	PetroNetwork S3 v3 CITLDS	variable	6 to 31	100,000	5 Tank Maximum =<100K Monthly throughput 2718K
20090006 Warren Rogers Assoc. (Renewal for 20040005)	PetroNetwork S3 v3 CITLDS	variable	6 to 31	100,000	5 Tank Maximum =<100K Monthly throughput 2718K
20070001 TotalSIR, LLC	TotalSIR Version 1.0	0.1	23	45,000	4 Tank Maximum =<45K
20040009 The Simmons Corp.	Simmons SIR 5.7 L.M.	0.1	27	60,000	5 Tank Maximum=<60K
20040002 Gilbarco-Veeder Root Ustman	USTMAN SIR Ver 95.2 95.2A 95.2B	0.05 0.1 0.16	30	60,000	4 Tank Maximum =<60,000
20010027 TeleData Inc.	TankMate SIR V3.2	.05 - 0.2	15	60,000	3 Tank Maximum =<60K
20000018 Horner Products, Inc.	Horner SIR PRO 1 V3.0	.1 to .2	23	45,000	4 Tank =<45K
990060 Entropy LTD	PTIC Rev. 90-12/93	0.05	30	60,000	60,000
960070 Warren Rogers Associates	WRA SIRA System v. 5.2	0.1	28	45,000	Tanks must be isolated.
930068 Horner Creative Products	SIR Pro 1	0.1	30	18,000	

ADDRESSES & PHONE #

Warren Rogers Associates
747 Aquidneck Avenue
Middletown, RI 02842
401-846-4747

Horner Products
104 Little Killarney Beach
Bay City, MI 48706
989-684-7972

The Simmons Corp.
106 E. Main St.
Richardson, TX 75081
800-848-8378

TotalSIR, LLC
20468-M Chartwell Center Dr.
Cornelius, NC 28031
704-892-8600