



# Leak Detection Test Reporting Requirements for EBW 960 AND 970 ATG models for CSLD

## BUREAU OF WEIGHTS AND MEASURES

PO Box 8911  
Madison, WI 53708  
(608) 224-4942  
datcp.wi.gov

## RESOURCES

[Wis. Admin. Code § ATCP 93.510](#)

[https://docs.legis.wisconsin.gov/code/admin\\_code/atcp/090/93/V/510](https://docs.legis.wisconsin.gov/code/admin_code/atcp/090/93/V/510)

[Wis. Admin Code § ATCP 93.515](#)

[https://docs.legis.wisconsin.gov/code/admin\\_code/atcp/090/93/V/515](https://docs.legis.wisconsin.gov/code/admin_code/atcp/090/93/V/515)

[Materials Approval Page](#)

[https://datcp.wi.gov/Pages/Programs\\_Services/MaterialApprovalsLeakDetection.aspx](https://datcp.wi.gov/Pages/Programs_Services/MaterialApprovalsLeakDetection.aspx)

[EBW](#)

<http://www.franklinfueling.com/americas/en>

[Approval #20020004](#)

<https://datcp.wi.gov/Documents/ER-BST-MA-20020004.pdf>

## When to submit your test results

- When renewing your annual Permit-to-Operate the owner/operator must supply the department with passing test reports of the 3 most current consecutive months of testing, and each test must be 28-32 days apart. For example, if your first test was June 1, the second test must be July 1, and the third test must be on August 1.
- When an inspection is conducted by the State of Wisconsin, at least 12 months of test reports must be available for review by a state inspector.
- Below is the CSLD test report example that the EBW 960 and 970 ATG system will print. You are required to submit the test report when renewing your annual permit to operate.

```
AUTOLEAK REPORT: Automatically prints
on day 25 when AutoLeak Mode is
turned < ON >.
AVAILABLE IN 24 HOUR
AUTOLEAK SOFTWARE ONLY

----- AUTOLEAK REPORT -----
THU JAN 25,96 9:46:28 AM
STATION NAME:
EBW TEST SITE
2814 McCRACKEN AVE.
(800) 475-5151
MUSKEGON, MI 49441

TANK 1 PRODUCT: NO LEAD

LEAK RATE: -0.09 gal/hr
PASS 0.2 GPH TEST

LEAK TEST START:
MON JAN 01,96 12:00:00 AM
TEST 1: 7.?? gal/hr
TEST 2: 0.09 gal/hr
TEST 3: 7.?? gal/hr
TEST 4: 7.?? gal/hr
TEST 5: 7.?? gal/hr
TEST 6: 7.?? gal/hr
LEAK TEST END:
SAT JAN 13,96 12:00:00 AM
```

If you have questions about how your EBW ATG system works please contact your service company or EBW directly. You can also find further information about your specific leak detection equipment on the materials approval page of our website. The OPW material approval number is 20020004.

## Leak detection FAQs

*What is leak detection?*

“Leak Detection” means determining whether a discharge of regulated substance has occurred from a storage tank system into the environment or into the space between the tank and its secondary barrier or containment.

*What is “ATG”?*

“Automatic Tank Gauging” (ATG) or “Automatic Leak Detection” means a leak detection or monitoring system that will provide continuous 24-hour monitoring for the detection of a

release or leak of vapor or product and will immediately communicate the detection of the release or leak to an electronic signaling device.

*What is CSLD?*

Wisconsin Administrative Code §§ ATCP 93.510 and 93.515 require all new and existing underground tank systems which store regulated substances to be provided with a method of leak detection. One of the acceptable methods of leak detection is “CSLD” (continuous leak detection).

Continuous Statistical Leak Detection (CSLD) monitors the product level and temperature in the tank at idle times. The system will continue to monitor the tank until it has gathered enough data to conclude that the tank system is tight, or there is a possible leak.