



Pressurized Line Leak Detection Test Reporting Requirements for the Franklin Fueling TS Series ATG System (all models except the TS-5)

BUREAU OF WEIGHTS AND MEASURES

PO Box 8911
Madison, WI 53708
(608) 224-4942
datcp.wi.gov

RESOURCES

[Wis. Admin. Code § ATCP 93.510](https://docs.legis.wisconsin.gov/code/admin_code/atcp/090/93/V/510)

https://docs.legis.wisconsin.gov/code/admin_code/atcp/090/93/V/510

[Wis. Admin Code § ATCP 93.515](https://docs.legis.wisconsin.gov/code/admin_code/atcp/090/93/V/515)

https://docs.legis.wisconsin.gov/code/admin_code/atcp/090/93/V/515

[Materials Approval Page](https://datcp.wi.gov/Pages/Programs_Services/MaterialApprovalsLeakDetection.aspx)
https://datcp.wi.gov/Pages/Programs_Services/MaterialApprovalsLeakDetection.aspx

[Franklin Fueling](http://www.franklinfueling.com/americas/en)
<http://www.franklinfueling.com/americas/en>

[Approval #20160005R1](https://datcp.wi.gov/Documents/TCP-WM-MA-20160005R1.pdf)
<https://datcp.wi.gov/Documents/TCP-WM-MA-20160005R1.pdf>

When to submit your test results

- When renewing your annual Permit-to-Operate the owner/operator must supply the department with passing test reports of the 3 most current consecutive months of testing, and each test must be 28-32 days apart. For example, if your first test was June 1, the second test must be July 1, and the third test must be on August 1.
- When an inspection is conducted by the State of Wisconsin, at least 12 months of test reports must be available for review by a state inspector.
- Below is a test example of the pressurized line leak detection printout for the Franklin Fueling TS series (all models except the TS-5) ATG System. You are required to submit the test report when renewing your annual permit to operate.

```
INCON INTELLIGENT CONTROLS INC
P.O. BOX 63B
SACO ME 040722

08/13/1998          10:16 AM

LINE COMPLIANCE REPORT

LINE NO. 1          REGULAR

PASSED MONTHLY TESTS

TEST TIME          1:42 AM
TEST DATE          08/12/1998
LINE TEST          0.20 GPH
LEAK RATE          0.00 GPH

TEST TIME          11:12 PM
TEST DATE          07/14/1998
LINE TEST          0.20 GPH
LEAK RATE          0.00 GPH

LINE NO. 2          MID GRAD

PASSED MONTHLY TESTS

TEST TIME          8:15 AM
TEST DATE          08/11/1998
LINE TEST          0.20 GPH
LEAK RATE          0.00 GPH

TEST TIME          4:41 AM
TEST DATE          07/14/1998
LINE TEST          0.20 GPH
LEAK RATE          0.00 GPH
```

If you have questions about how your Franklin Fueling Management ATG system works please contact your service company or Franklin Fueling directly. You can also find further information about your specific leak detection equipment on the materials approval page of our website. The Franklin Fueling material approval number is 20160005R1.

Pressurized Line Leak Detection Test Reporting Requirements for the Franklin Fueling TS Series ATG System (all models except the TS-5)

Leak detection FAQs

What is leak detection?

“Leak Detection” means determining whether a discharge of regulated substance has occurred from a storage tank system into the environment or into the space between the tank and its secondary barrier or containment.

What is “ATG”?

“Automatic Tank Gauging” (ATG) or “Automatic Leak Detection” means a leak detection or monitoring system that will provide continuous 24-hour monitoring for the detection of a release or leak of vapor or product and will immediately communicate the detection of the release or leak to an electronic signaling device.

What is Pressurized Line Leak Detection Monitoring?

[Wisconsin Administrative Code §§ ATCP 93.510](#) and [93.515](#) require all new and existing underground tank piping systems which store regulated substances to be provided with a method of leak detection. One of the acceptable methods of leak detection is pressurized line leak detection (LLD) testing.

Pressurized line leak detectors operate during idle periods by independently pressurizing the pipeline system, then isolating the system from the pump and monitoring the pressure drop. The pressure drop is measured for several pressurization cycles. When the leak detection system determines that thermal effects have been sufficiently reduced, it compares the final pressure drop with a preset limit. If the pressure drop exceeds that limit, a leak is declared.