



Clearances Required in Fuel Dispensing Area

BUREAU OF WEIGHTS AND MEASURES

PO Box 8911
Madison, WI 53708
(608) 224-4942
datcp.wi.gov

RESOURCES

Wis. Admin. Code ATP 93
https://docs.legis.wisconsin.gov/code/admin_code/atcp/090/93

NPFA 30A
<https://www.nfpa.org/en>

There are many safety risks associated with the practice of displaying merchandise and other materials within the fuel dispensing area. Wisconsin Administrative Code ATP 93 and NFPA 30A set clear criteria for dispensing area safety in order to:

- Control the dispenser area for ignition sources
- Provide adequate egress for individuals exiting the dispenser area in case of an emergency
- Allow emergency responders and their equipment proper access to the dispensing area
- Mitigate a fire and keep it from spreading to vehicles and structures on the service station property
- Allow the attendant to adequately observe and monitor what is taking place in the dispensing area

In order to reduce the safety risks, follow these requirements:

- **Combustible merchandise** placed within 20 feet of the dispenser including pallets and packaging material are not permitted within 3 feet horizontally of the dispenser cabinet. The display may not stand higher than 3 feet above grade per Wis. Admin. Code § ATP 93.620(2)(e)(1) & (2).
- **LPG cylinders** and other similar fuels are not permitted within 20 feet of any fuel dispenser per Wis. Admin. Code § ATP 93.620(2)(b).
- **Class I Liquids** other than the fuel being dispensed are not permitted within 20 feet of any fuel dispenser per Wis. Admin. Code § ATP 93.620(2)(c).
- **Vending machines/ATMs** and other equipment or devices not required for or not integral to the fueling operation must be installed outside of the fuel dispensing area per Wis. Admin. Code § ATP 93.620(2)(a).
- **All surface area** within a 30-foot radius of the dispenser must be free of high grass, weeds, and debris per Wis. Admin. Code § ATP 93.605(3)(c).
- **Trash receptacles and window washing containers** for public use are permitted within the dispensing area per Wis. Admin. Code § ATP 93.620.

For examples of compliant and non-compliant dispenser areas, please see next page.

Clearances Required in Fuel Dispensing Area



Compliant merchandising display in dispensing area



Non-compliant – Display is too high



Non-compliant – Display is too high and too close to the dispenser



Non-compliant - Display is too high and unbalanced