



# Important Tank System Deadlines

## BUREAU OF WEIGHTS AND MEASURES

PO Box 8911  
Madison, WI 53708  
(608) 224-4942  
datcp.wi.gov

## RESOURCES

Wis. Admin. Code ATCP 93  
[http://docs.legis.wisconsin.gov/code/admin\\_code/atcp/090/93](http://docs.legis.wisconsin.gov/code/admin_code/atcp/090/93)

Storage Tanks Website  
[https://datcp.wi.gov/Pages/Programs\\_Services/PetroleumHazStorageTanks.aspx](https://datcp.wi.gov/Pages/Programs_Services/PetroleumHazStorageTanks.aspx)

Wisconsin Administrative Code ATCP 93 requires certain secondary containment requirements to be met by January 1, 2021. As a result of the COVID-19 pandemic and the impact the public health emergency has had on industry, the department intends to delay enforcement of secondary containment requirements until after the following dates:

### Underground Storage Tank (UST) upgrades

**January 1, 2022** - ATCP 93.500(5)(d): All existing pipe connections at the top of the tank and beneath all freestanding pumps and dispensers that routinely contain product shall be placed within secondary containment sumps

**January 1, 2022** - ATCP 93.500(5)(f)1: Secondary containment sumps provided under this subsection shall have non-discriminating electronic sensors to detect liquids located in the lowest collection point of the sump, unless approved otherwise by the department

### Aboveground Storage Tank (AST) upgrades

**January 1, 2022** – ATCP 93.400(3)(d): All pipe connections at a dispenser for motor vehicle fueling that were in existence or under construction before February 1, 2009, shall be placed within a secondary containment sump

**January 1, 2022** – ATCP 93.400(3)(h)1: Secondary containment sumps provided under this subsection shall have non-discriminating electronic sensors that will detect liquids in the sump, unless approved otherwise by the department

### Plan Ahead - Do Not Risk Shutdown

If you have questions concerning compliance issues at your facility, contact the Weights and Measures Petroleum System Inspector for your area. Contact information for inspectors can be found on our website here:

[https://datcp.wi.gov/Pages/Programs\\_Services/StorageTankContacts.aspx](https://datcp.wi.gov/Pages/Programs_Services/StorageTankContacts.aspx)