



Important Tank System Deadlines

Underground Storage Tank (UST) upgrades:

Feb 1, 2010	Periodic inspection of UST systems ♦ ATCP § 93.500(8)
Feb 1, 2011	Auto shutoff overfill protection ♦ ATCP § 93.505(2)(b)
Jan 1, 2012	Designation of Class A, B, and C operators ♦ ATCP § 93.820(1)
Dec 31, 2020	Pipe connections at top of tank and beneath pumps and dispensers shall be in secondary containment ♦ Wis. Stat. § 101.09(3m)(b)

Aboveground Storage Tank (AST) upgrades:

Feb 1, 2010	Periodic inspection of AST systems ♦ ATCP § 93.440(1)
Feb 1, 2010	Containment for fill not located in a dike ♦ ATCP § 93.410(6)
Feb 1, 2011	Corrosion protection on underground piping from an AST ♦ ATCP § 93.400(2)(c)
Feb 1, 2011	Leak detection for underground piping from an AST ♦ ATCP § 93.400(4)(a)
Aug 1, 2011	Overfill prevention on ASTs with fill point not in a dike ♦ ATCP § 93.410(9)
Dec 31, 2011	Emergency shutoff for transfers from a fixed tank to a tank vehicle, rail tank car, or vehicle fuel tank ♦ ATCP § 93.370
Dec 31, 2011	Secondary containment for product transfers at bulk plants and terminals ♦ ATCP § 93.340(5)
Dec 31, 2014	Secondary containment for Hazardous Substance ASTs ♦ ATCP § 93.350(3)(j)2
Dec 31, 2014	Secondary containment for Hazardous Substance product transfers ♦ ATCP § 93.350(5)(b)1.b.
Dec 31, 2020	Pipe connection at dispenser shall be in secondary containment ♦ Wis. Stat. § 101.09(3m)(b)

Plan Ahead - Do Not Risk Shutdown

If you have questions concerning compliance issues at your facility, contact the Weights and Measures Petroleum System Inspector for your area. A map of inspector territories can be found at:

https://datcp.wi.gov/Documents/WM_Gen_Insp_Territories.pdf