



Storage Tank Registration Requirements

BUREAU OF WEIGHTS & MEASURES

PO Box 8911
Madison, WI 53708
608-224-4942
datcp.wi.gov

RESOURCES

Wis. Admin. Code ATCP 93:
http://docs.legis.wisconsin.gov/code/admin_code/atcp/090/93

Storage Tanks Website:
https://datcp.wi.gov/Pages/Programs_Services/PetroleumHazStorageTanks.aspx

Storage Tanks Forms Page:
https://datcp.wi.gov/Pages/Programs_Services/PetroleumHazStorageTanksForms.aspx

Wisconsin Administrative Code ATCP 93 requires all new or existing storage tanks that are used to store flammable, combustible, or hazardous liquids must be registered with the Department of Agriculture, Trade and Consumer Protection (DATCP), with the exception of:

- Aboveground storage tanks with a capacity of less than 1,100 gallons that are:
 - farm tanks
 - located at and serve a construction project
 - used to store heating or used oil for consumptive use on the property
 - used to store Class IIIB liquids other than used oil
 - are located inside a building and are used for industrial processes if that use occurs through piping which connects the tank to the process
- Aboveground tanks which are used to store non-flammable or non-combustible federally regulated hazardous substances and which have a capacity of less than 5,000 gallons
- Tank vehicles
- Tank wagons, portable tanks and movable tanks, that are located on a property for less than 24 months
- Tanks that are located at a US EPA superfund site

To register a storage tank, the proper form must be submitted to the department within 15 business days of completion of the installation.

- Underground storage tanks must be registered using form TR-WM-137
- Aboveground storage tanks must be registered using form TR-WM-118
- Adobe PDF and fillable Microsoft Word versions of the registration forms are available on the [DATCP website](#)

An owner of a tank system that changes their name, mailing address, or the facility name is required to notify DATCP within 15 business days of the change.

Questions? Please contact our permitting department at (608)224-4942, option 3, or by email at datcpweightsandmeasures@wi.gov.