

Storage Tank Registration Requirements

Wisconsin Administrative Code ATCP 93 requires all new or existing storage tanks that are used to store flammable, combustible, or hazardous liquids must to be registered with the Department of Agriculture, Trade and Consumer Protection (DATCP), with the exception of:

- Aboveground storage tanks with a capacity of less than 5,000 gallons
- Tank vehicles
- Portable tanks and movable tanks, that are located on a property for less than 24 months
- Tanks that are located at a US EPA superfund site

To register a storage tank, the proper form must be submitted to the department within 15 business days of completion of the installation.

- Underground storage tanks must be registered using form TR-WM-137
- Aboveground storage tanks must be registered using form TR-WM-118
- Adobe PDF and fillable Microsoft Word versions of the registration forms are available on the <u>DATCP website</u>

An owner of a tank system that changes their name, mailing address, or the facility name is required to notify DATCP within 15 business days of the change.

Questions? Please contact our permitting department at (608)224-4942, option 3, or by email at <u>datcpstoragetanks@wisconsin.gov</u>.

BUREAU OF WEIGHTS AND MEASURES

PO Box 8911 Madison, WI 53708 (608) 224-4942 datcp.wi.gov

RESOURCES

Wis. Admin. Code ATCP 93 http://docs.legis.wisconsin .gov/code/admin_code/at cp/090/93

Storage Tanks Website https://datcp.wi.gov/Pages /Programs_Services/Petrol eumHazStorageTanks.aspx

Storage Tanks Forms Page https://datcp.wi.gov/Page s/Programs_Services/Petr oleumHazStorageTanksFor ms.aspx

Storage Tank Fact Sheets: https://datcp.wi.gov/Page s/Publications/WeightsAn dMeasuresBureauFactShe ets.aspx