

Wisconsin Department of Agriculture, Trade and Consumer Protection

Division of Trade and Consumer Protection

Your application will not be processed or will be delayed unless you:

Mail to: DATCP – TCP, Attn: Petroleum Certification, PO Box 7837,

Madison, WI 53707-7937

Phone: (608) 224-4942 Email: <u>DATCPWeightsAndMeasures@wisconsin.gov</u>

FOR OFFICE USE ONLY				
DATE ISSUED:				
CERT NUMBER:				
DATE RECEIVED:				

TANK SYSTEM INSPECTOR EXAM APPLICATION

Wis. Stats. §§101 and 168 Wis. Admin. Code §ATCP 93.240

NOTE: It is recommended that you make a photoc	•		S.	
APPLICANT INFORMATION				
NAME OF APPLICANT (first, middle, last)				YEAR OF BIRTH
STREET ADDRESS OR PO BOX	CITY		STATE	ZIP + 4 CODE
EMAIL ADDRESS (if available)		PHONE (including are	ea code) C	ELL PHONE:
MAIL APPLICATION				
Return this completed and signed form to: DATCP – TCP Attn: Petroleum Certification PO Box 7837 Madison, WI 53707-7937				
QUALIFICATIONS FOR EXAMINATION				
A person applying to take a tank system inspector course or training program. Applicant must preser is offered at Lakeshore Technical College. For a sphone: (920) 693-1167 or email: ruth.semph@goto	ent a photo ID to gain admittand schedule, visit their website <u>htt</u> toltc.edu	ce to an examination p://gotoltc.edu/	on. The contact R	course and exam uth Semph by
NOTE: You still need to complete and submit this In order to receive the certification, the applicant m				

ATCP 93 – Flammable, Combustible and Hazardous Liquids Code

NFPA 30 - Flammable and Combustible Liquids Code

NFPA 30A - Code for Motor Fuel Dispensing Facilities and Repair Garages

PEI 100 - Recommended Practices for Installation of Underground Liquid Storage Systems

PEI 200 - Recommended Practices for Installation of Aboveground Storage Systems for Motor Vehicle Fueling

Exam Materials:

book and will cover:

- For copies of current Wisconsin administrative code books visit the DATCP website: http://datcp.wi.gov/
- For NFPA materials contact the National Fire Protection Association by phone: (800) 344-3555.
- For PEI materials contact the Petroleum Equipment Institute by phone: (918) 494-9696:

EDUCATION HOURS REQUIRED TO RENEW

The renewal of a certification as a Tank System Inspector shall be contingent upon the installer obtaining at least 12 hours of acceptable continuing education prior to the expiration date of their certification.

RESPONSIBILITIES OF CERTIFICATION

A person who inspects tank systems as a certified tank system inspector shall:

- Perform regulatory enforcement of related code requirements in ch. ATCP 93
- Issue non-compliance or violation-correction orders and conduct follow-up inspections as necessary to verify correction.
- Pursue failure to comply with correction orders through local or department enforcement referral procedures.
- Maintain a record of the inspections made including the dates and the findings of the inspections
- Provide a copy of the inspection report to the owner of the tank system owner or his or her agent
- Make available to the department upon request his or her tank system inspection records

ACKNOWLE	DGEMENT
----------	---------

By signing below, the applicant certifies that all information provided on this application is true, accurate and that the certification requirements are met.

Notice: Information including personally identifiable approvals, law enforcement (including child support and purposes other than that for which it was origing provide this information to requesters pursuant to unumbers are required when individuals apply for a anyone except other State of Wisconsin government to be entered on this form.	t and tax delinquency enforcement) purpose, other nally collected. (sec. 15.04(1)(m), Wis. Stats.). The Visconsin's open records law, ss. 19.31-19.39, Wis license according to Wisconsin Stats., but they may	secondary purposes Department may also . Stats. Social security not be disclosed to
PRINT NAME OF APPLICANT	SIGNATURE OF APPLICANT	DATE (MM/DD/YYYY)