



Test Reporting Requirements for Veeder-Root ATG Interstitial Monitoring Leak Detection for the TLS-450 model

BUREAU OF WEIGHTS AND MEASURES

PO Box 8911
Madison, WI 53708
(608) 224-4942
datcp.wi.gov

RESOURCES

[Wis. Admin. Code § ATCP 93.510](#)

https://docs.legis.wisconsin.gov/code/admin_code/atcp/090/93/V/510

[Wis. Admin Code § ATCP 93.515](#)

https://docs.legis.wisconsin.gov/code/admin_code/atcp/090/93/V/515

[Materials Approval Page](#)

https://datcp.wi.gov/Pages/Programs_Services/MaterialApprovalsLeakDetection.aspx

[Veeder-Root](#)

<http://www.veeder.com/us/>

[Approval #20130002](#)

<https://datcp.wi.gov/Documents/TCP-WM-MA-20130002.pdf>

When to submit your test results

- When renewing your annual Permit-to-Operate the owner/operator must supply the department with passing test reports of the 3 most current consecutive months of testing, and each test must be 28-32 days apart. For example, if your first test was June 1, the second test must be July 1, and the third test must be on August 1.
- When an inspection is conducted by the State of Wisconsin, at least 12 months of test reports must be available for review by a state inspector.
- Below is the Interstitial Monitoring test report example that the Veeder-Root TLS-450 ATG system will print. You are required to submit the test report when renewing your annual permit to operate.

SEP 1, 2015 5:00 AM		
BUSINESS NAME		
ADDRESS		
CITY		
STATE, ZIP CODE		
LIQUID STATUS REPORT		
SENSOR	LOCATION	STATUS
L 1	UNLEADED INTERSTITIAL	NORMAL
L 2	DIESEL INSTERTSTITAL	NORMAL
SEP 1, 2015 5:01 AM		
BUSINESS NAME		
ADDRESS		
CITY		
STATE, ZIP CODE		
SENSOR STATUS REPORT - ALL SENSORS		
#	SENSOR LOCATION	STATUS
L 1	UNLEADED INTERSTITIAL	NORMAL
L 2	DIESEL INSTERTSTITAL	NORMAL

If you have questions about how your Veeder-Root ATG system works please contact your service company or Veeder-Root directly. You can also find further information about your specific leak detection equipment on the materials approval page of our website. The Veeder-Root material approval number is 20130002.

Leak detection FAQs

What is leak detection?

“Leak Detection” means determining whether a discharge of regulated substance has occurred from a storage tank system into the environment or into the space between the tank and its secondary barrier or containment.

What is “ATG”?

“Automatic Tank Gauging” (ATG) or “Automatic Leak Detection” means a leak detection or monitoring system that will provide continuous 24-hour monitoring for the detection of a release or leak of vapor or product and will immediately communicate the detection of the release or leak to an electronic signaling device.

What is Interstitial Monitoring?

[Wisconsin Administrative Code §§ ATCP 93.510](#) and [93.515](#) require all new and existing underground tank systems which store regulated substances to be provided with a method of leak detection. One of the acceptable methods of leak detection is “Interstitial Monitoring”.

Interstitial monitoring is a leak detection method that entails the surveillance of the space between a tank system’s walls and the secondary containment system, for a change in the steady-state conditions.