

Date:

Wis. Admin Code ch. ATPC 76

[illegible]

*Liquid chemical feed must stop when power is interrupted to recirculation pump, when emergency stop button is pushed, and for pools built after February 1, 2009, any time the flow of water through the recirculation system stops. Anti-entrapment systems such as Safety Vacuum Release Systems (SVRSs) must work properly to stop pump. **Safety equipment includes first aid kit and biohazard kit, blankets for most whirlpools, and telephone. Personally identifiable information you provide may be used for purposes other than that for which it was collected. (Wis. Stat. §15.04 (1)(m)).