

Test Reporting Requirements for the Franklin Fueling TS-5 Series (all models) ATG using the LS-300 or the TS-LLD Pressurized Line Leak Detection System

When to submit your test results

- When renewing your annual Permit-to-Operate the owner/operator must supply the department with <u>passing</u> test reports of the 3 most current consecutive months of testing, and each test must be 28-32 days apart. For example, if your first test was June 1, the second test must be July 1, and the third test must be on August 1.
- When an inspection is conducted by the State of Wisconsin, at least 12 months of test reports must be available for review by a state inspector.
- Below is a test report example of the pressurized line leak detection log for the for the Franklin Fueling TS-5 series (all models) ATG using the LS-300 or the TS-LLD line leak detection system. Both of these line leak detection systems are not able to print test reports, the operator must keep a monthly manual log.

Date	Time of Day	Line #	Procision test Passed?* Y or N		Atarm Indications**	Push Test/Reset**
			Monthly Annual			
					and the second of the second	
_		-				
_		-	-			
	3		1.			
_						10
	-	-				
	16-	2	1			
			12 11			
-		-				
11-12						
		3	1			
		-	-			
						-
			2 2			
			5 - C	- 3		
		-	-			
-		-				
1.1.1				100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100 - 100		
Annual (Flooring Innation After test uits avery TES: Test res Month ys Test Test Test Test Test Test	1 GPH) helt j ALARM lamp results are in y two weeks. Ut recording or Annual tes Comp will RE DUING-tem FLASH-so FLASH-so to to sage 5-5	assed and may be in should not it INK if coin- MAIN SOL p bycles of p bycles of p bycles of it for comp	ication by doubt dication of syst ess TESTARCS take place dan g a precision ta JC if doing a 3 g at time or an seconds off an seconds off an	ET button, Pest I ng e line loak toet st GPH test, dief af brief an oprinformedien	SH Flamp inclositors and st passed famp indi- Ses ange 9-5 for a	refor to page 6-6 for more califore will be descell. Recor mp indications agriculary a Cin A results while dispensing.
	100.000.000		0-0000000000000000000000000000000000000			Carlos and a second

If you have questions about how your Franklin Fueling Management ATG system works please contact your service company or Franklin Fueling directly. You can also find further information about your specific leak detection equipment on the materials approval page of our website. The Franklin Fueling material approval number is 20160005R1.

BUREAU OF WEIGHTS AND MEASURES

PO Box 8911 Madison, WI 53708 (608) 224-4942 datcp.wi.gov

RESOURCES

Wis. Admin. Code § ATCP 93.510 https://docs.legis.wisconsi n.gov/code/admin_code/a tcp/090/93/V/510

<u>Wis. Admin Code § ATCP</u> <u>93.515</u> https://docs.legis.wisconsi n.gov/code/admin_code/a tcp/090/93/V/515

Materials Approval Page https://datcp.wi.gov/Page

s/Programs_Services/Mate rialApprovalsLeakDetectio n.aspx

<u>Franklin Fueling</u> http://www.franklinfueling .com/americas/en

Approval #20160005R1 https://datcp.wi.gov/Docu ments/TCP-WM-MA-20160005R1.pdf

Leak detection FAQs

What is leak detection?

"Leak Detection" means determining whether a discharge of regulated substance has occurred from a storage tank system into the environment or into the space between the tank and its secondary barrier or containment.

What is "ATG"?

"Automatic Tank Gauging" (ATG) or "Automatic Leak Detection" means a leak detection or monitoring system that will provide continuous 24-hour monitoring for the detection of a release or leak of vapor or product and will immediately communicate the detection of the release or leak to an electronic signaling device.

What is Pressurized Line Leak Detection Monitoring?

<u>Wisconsin Administrative Code §§ ATCP 93.510</u> and <u>93.515</u> require all new and existing underground tank piping systems which store regulated substances to be provided with a method of leak detection. One of the acceptable methods of leak detection is pressurized line leak detection (LLD) testing.

Pressurized line leak detectors operate during idle periods by independently pressurizing the pipeline system, then isolating the system from the pump and monitoring the pressure drop. The pressure drop is measured for several pressurization cycles. When the leak detection system determines that thermal effects have been sufficiently reduced, it compares the final pressure drop with a preset limit. If the pressure drop exceeds that limit, a leak is declared.